

Shower Head Descaling Record

A shower head and hose descaling record for legionella control: each outlet with its location, condition, descale and disinfection, temperatures and result, against the HSG274 quarterly frequency.

1. Visit

Project

Client

Site *

Site address

Date *

Time

Done by *

Descaler and disinfectant used

HSE HSG274 Part 2: dismantle, clean and descale removable parts, heads, inserts and hoses of showers and spray taps quarterly, or more often as the rate of fouling or other risk factors indicate, for example areas with high-risk patients.

2. Outlets

Outlets by floor, room or area (copy this block for each one)

Floor, room or area *

For example First floor changing room

Showers and spray taps here (copy this block for each one)

Position in this room *

Scan the outlet tag

Scanned in the SiteSurvey app. On paper, write the numbers: asset number.

Type (choose one)

☐ Shower head and hose ☐ Fixed shower head ☐ Spray tap ☐ Emergency shower

Scale or biofilm found (choose one)

☐ None ☐ Light ☐ Heavy

Dismantled, cleaned and descaled?

☐ Yes ☐ No

Head or hose replaced?

☐ Yes ☐ No

Thermostatic mixing valve (TMV) fitted?

☐ Yes ☐ No

Temperature at the outlet after 1 minute (°C)

If applicable: Below 50 °C after one minute with no TMV. HSG274 says hot water should reach outlets at 50 °C (55 °C in healthcare premises) within one minute. Report it to the responsible person.

Result * (choose one)

☐ Done ☐ Not done: no access ☐ Not done: defect

Notes (if applicable)

Photos (before and after) (photos: attach, or note the file names)

This room or area: outlets done (worked out automatically in the app)

This room or area: outlets with heavy scale (worked out automatically in the app)

Outlets done (worked out automatically in the app)

Outlets with heavy scale (worked out automatically in the app)

If applicable: Heavy scale found. HSG274 allows a shorter interval than quarterly where the rate of fouling indicates it.

3. Sign-off


Next clean due

Days to the next clean (if applicable; worked out automatically in the app)

If applicable: The next clean date is before the date of this record. Check the date.

Site contact name

Site contact signature



Completed by *

Signature